

ADVANCED AIR ANALYSIS, INC.

ASBESTOS AIR SAMPLING FORM

DATE: 09-27-19 JOB # 19816 # OF SAMPLES: 16

PROJECT NAME: Hilton ES

CLIENT: Towson Mechanical

CONTRACTOR: A-L

IH NAME: Danny Pospelov SIGNATURE *Danny Pospelov*

MICROSCOPE MODEL # Olympus CH-2

MICROSCOPE SERIAL # M0099

HSE/NPL SLIDE CALIBRATION LFV4 FCI 6

OCULAR PHASE RING CALIBRATION YES NO

PAGE # 1 OF 3

SAMPLE NUMBER	SAMPLE TYPE / PUMP ID	SAMPLE LOCATION	START TIME / FLOW	STOP TIME / FLOW	TOTAL TIME (MIN)	VOLUME (LITERS)	FIBERS / FIELDS	DET. LIMIT	F/CC	COMMENTS
	QA / QC	SAMPLE # AAR D 126					100 / 91		139.98	Range 41 to 144
	DUPLICATE	SAMPLE # 19816-0927-14					2.5 / 100	0.010	<0.010	OK D.P.
	BLANK	LAB BLANK								
	BLANK	FIELD BLANK								
19816-0927-01	BLANK	FIELD BLANK					0 / 100			
19816-0927-02	BLANK	FIELD BLANK					0 / 100			
19816 0927 03	OA / DP1-H	Outside WA - 1st Floor - Hallway Teacher's Lounge 101 Entrance	12:00 / 9.5	13:05 / 9.5	65	617.5	.5 / 100	0.010	<0.010	
19816 0927 04	OA / DP2-H	Outside WA - 1st Floor - Hallway Near Room 116	12:02 / 9.5	13:07 / 9.5	65	617.5	0 / 100	0.010	<0.010	
19816 0927 05	OA / DP3-H	Outside WA - 2nd Floor - Hallway Teacher's Lounge 202 Entrance	12:05 / 9.5	13:10 / 9.5	65	617.5	1 / 100	0.010	<0.010	
19816 0927 06	OA / DP4-H	Outside WA - 2nd Floor - Hallway Near Room 215	12:07 / 9.5	13:12 / 9.5	65	617.5	.5 / 100	0.010	<0.010	

AM - AMBIENT AIR SAMPLE BS - BACKGROUND AIR SAMPLE OA - OUTSIDE WORK AREA FC - FINAL CLEARANCE HP - EXHAUST OF HEPA NEGATIVE PRESSURE UNIT PS - PERSONAL AIR SAMPLE WA - INSIDE WORK AREA EX - 30 MINUTE BREATHING ZONE DURING PEAK REMOVAL

ADVANCED AIR ANALYSIS, INC.

ASBESTOS AIR SAMPLING FORM

PROJECT NAME: Hilton ES

DATE: 09-27-19

JOB # 19816

IH NAME: Danny Pospelov

OF SAMPLES: 16

PAGE # 2 OF 3

SIGNATURE Danny Pospelov

SAMPLE NUMBER	SAMPLE TYPE / PUMP ID	SAMPLE LOCATION	START TIME / FLOW	STOP TIME / FLOW	TOTAL TIME (MIN)	VOLUME (LITERS)	FIBERS / FIELDS	DET. LIMIT	F/CC	COMMENTS
19816 0927 07	FC DP5-H	Final - Inside WA - 1st Floor - Teacher's Lounge 101	12:10 9.5	13:15 9.5	65	617.5	1 100	0.010	<0.010	
19816 0927 08	FC DP6-H	Final - Inside WA - 1st Floor - Teacher's Lounge 101	12:11 9.5	13:16 9.5	65	617.5	0 100	0.010	<0.010	
19816 0927 09	FC DP7-H	Final - Inside WA - 1st Floor - Teacher's Lounge 101	12:12 9.5	13:17 9.5	65	617.5	0 100	0.010	<0.010	
19816 0927 10	FC DP8-H	Final - Inside WA - 1st Floor - Teacher's Lounge 101	12:13 9.5	13:18 9.5	65	617.5	1.5 100	0.010	<0.010	
19816 0927 11	FC DP9-H	Final - Inside WA - 1st Floor - Teacher's Lounge 101	12:14 9.5	13:19 9.5	65	617.5	.5 100	0.010	<0.010	
19816 0927 12	FC DP1-H	Final - Inside WA - 2nd Floor - Teacher's Lounge 201	13:06 9.5	14:11 9.5	65	617.5	1 100	0.010	<0.010	
19816 0927 13	FC DP2-H	Final - Inside WA - 2nd Floor - Teacher's Lounge 201	13:10 9.5	14:15 9.5	65	617.5	1 100	0.010	<0.010	
19816 0927 14	FC DP3-H	Final - Inside WA - 2nd Floor - Teacher's Lounge 201	13:11 9.5	14:16 9.5	65	617.5	2 100	0.010	<0.010	
19816 0927 15	FC DP4-H	Final - Inside WA - 2nd Floor - Teacher's Lounge 201	13:12 9.5	14:17 9.5	65	617.5	0 100	0.010	<0.010	

AM - AMBIENT AIR SAMPLE OA - OUTSIDE WORK AREA HP - EXHAUST OF HEPA NEGATIVE PRESSURE UNIT PS - PERSONAL AIR SAMPLE
 BS - BACKGROUND AIR SAMPLE FC - FINAL CLEARANCE WA - INSIDE WORK AREA EX - 30 MINUTE BREATHING ZONE DURING PEAK REMOVAL

