

ADVANCED AIR ANALYSIS, INC.

ASBESTOS AIR SAMPLING FORM

DATE: 9/27/2019 JOB # 19816 # OF SAMPLES: 73

PROJECT NAME: Hilton ES
 CLIENT: Towson Mechanical, Inc.
 CONTRACTOR: A-L
 IH NAME: Timothy Brice / Michael Kagan SIGNATURE _____

MICROSCOPE MODEL # Olympus CH-2
 MICROSCOPE SERIAL # 3C0018
 HSE/NPL SLIDE CALIBRATION LFV4 FCI 6
 OCULAR PHASE RING CALIBRATION YES NO
 PAGE # 1 OF 9

SAMPLE NUMBER	SAMPLE TYPE / PUMP ID	SAMPLE LOCATION	START TIME / FLOW	STOP TIME / FLOW	TOTAL TIME (MIN)	VOLUME (LITERS)	FIBERS / FIELDS	DET. LIMIT	F/CC	COMMENTS
	QA / QC	SAMPLE # AAR-126-D					83 / 100		105.73	Range 41 to 144 TB
	DUPLICATE	SAMPLE # 19816-0927-03					8.5 / 100	0.010	<0.010	OK TB
	BLANK	LAB BLANK								
	BLANK	FIELD BLANK								
01	BLANK	FIELD BLANK					0 / 100			
02	BLANK	FIELD BLANK					0 / 100			
19816 0927 03	OA / TB1-L	1st Floor - Hallway - Next to Room 106	0730 / 2.5	1500 / 2.5	450	1125	7.5 / 100	0.010	<0.010	
19816 0927 04	OA / TB2-L	1st Floor - Hallway - Next to Room 117	0731 / 2.5	1501 / 2.5	450	1125	6.0 / 100	0.010	<0.010	
19816 0927 05	OA / TB3-L	2nd Floor - Hallway - Next to Room 207	0732 / 2.5	1502 / 2.5	450	1125	9.0 / 100	0.010	<0.010	
19816 0927 06	OA / TB4-L	2nd Floor - Hallway - Next to Room 218	0733 / 2.5	1503 / 2.5	450	1125	5.5 / 100	0.010	<0.010	
19816 0927 07	OA / TB1-H	1st Floor - Room 200 - Center of Area	0730 / 9.5	0836 / 9.5	66	627	3.0 / 100	0.010	<0.010	

AM - AMBIENT AIR SAMPLE OA - OUTSIDE WORK AREA HP - EXHAUST OF HEPA NEGATIVE PRESSURE UNIT PS - PERSONAL AIR SAMPLE
 BS - BACKGROUND AIR SAMPLE FC - FINAL CLEARANCE WA - INSIDE WORK AREA EX - 30 MINUTE BREATHING ZONE DURING PEAK REMOVAL

ADVANCED AIR ANALYSIS, INC.

ASBESTOS AIR SAMPLING FORM

PROJECT NAME: Hilton ES

DATE: 9/27/2019

JOB # 19816

IH NAME: Timothy Brice / Michael Kagan SIGNATURE _____

OF SAMPLES: 73

PAGE # 2 OF 9

SAMPLE NUMBER	SAMPLE TYPE / PUMP ID	SAMPLE LOCATION	START TIME / FLOW	STOP TIME / FLOW	TOTAL TIME (MIN)	VOLUME (LITERS)	FIBERS / FIELDS	DET. LIMIT	F/CC	COMMENTS
19816 0927 13	OA TB2-H	1st Floor - Room 110 - Center of Area	0815 9.5	0921 9.5	66	627	3.0 100	0.010	<0.010	
19816 0927 14	OA TB3-H	2nd Floor - Room 209 - Center of Area	0815 9.5	0921 9.5	66	627	4.0 100	0.010	<0.010	
19816 0927 20	OA TB4-H	1st Floor - Room 111 - Center of Area	0910 9.5	1016 9.5	66	627	2.0 100	0.010	<0.010	
19816 0927 21	OA TB1-H	2nd Floor - Room 210 - Center of Area	0910 9.5	1016 9.5	66	627	4.5 100	0.010	<0.010	
19816 0927 27	OA TB2-H	1st Floor - Room 112 - Center of Area	1000 9.5	1106 9.5	66	627	3.0 100	0.010	<0.010	
19816 0927 28	OA TB3-H	2nd Floor - Room 211 - Center of Area	1000 9.5	1106 9.5	66	627	4.0 100	0.010	<0.010	
19816 0927 34	OA TB4-H	1st Floor - Room 113 - Center of Area	1055 9.5	1201 9.5	66	627	5.0 100	0.010	<0.010	
19816 0927 35	OA TB1-H	2nd Floor - Room 212 - Center of Area	1055 9.5	1201 9.5	66	627	2.5 100	0.010	<0.010	
19816 0927 41	OA TB2-H	1st Floor - Room 114 - Center of Area	1130 9.5	1236 9.5	66	627	4.0 100	0.010	<0.010	

AM - AMBIENT AIR SAMPLE OA - OUTSIDE WORK AREA HP - EXHAUST OF HEPA NEGATIVE PRESSURE UNIT PS - PERSONAL AIR SAMPLE
 BS - BACKGROUND AIR SAMPLE FC - FINAL CLEARANCE WA - INSIDE WORK AREA EX - 30 MINUTE BREATHING ZONE DURING PEAK REMOVAL

ADVANCED AIR ANALYSIS, INC.

ASBESTOS AIR SAMPLING FORM

PROJECT NAME: Hilton ES DATE: 9/27/2019 JOB # 19816
 IH NAME: Timothy Brice / Michael Kagan SIGNATURE _____ # OF SAMPLES: 73 PAGE # 3 OF 9

SAMPLE NUMBER	SAMPLE TYPE / PUMP ID	SAMPLE LOCATION	START TIME / FLOW	STOP TIME / FLOW	TOTAL TIME (MIN)	VOLUME (LITERS)	FIBERS/ FIELDS	DET. LIMIT	F/CC	COMMENTS
19816 0927 42	OA TB3-H	2nd Floor - Room 213 - Center of Area	1130 9.5	1236 9.5	66	627	3.5 100	0.010	<0.010	
19816 0927 48	OA TB4-H	1st Floor - Room 115 - Center of Area	1205 9.5	1311 9.5	66	627	2.5 100	0.010	<0.010	
19816 0927 49	OA TB1-H	2nd Floor - Room 214 - Center of Area	1205 9.5	1311 9.5	66	627	5.0 100	0.010	<0.010	
19816 0927 55	OA TB2-H	1st Floor - Room 116 - Center of Area	1240 9.5	1346 9.5	66	627	3.5 100	0.010	<0.010	
19816 0927 56	OA TB3-H	2nd Floor - Room 216 - Center of Area	1240 9.5	1346 9.5	66	627	4.0 100	0.010	<0.010	
19816 0927 62	OA TB4-H	1st Floor - Room 117 - Center of Area	1320 9.5	1426 9.5	66	627	2.0 100	0.010	<0.010	
19816 0927 63	OA TB1-H	2nd Floor - Room 217 - Center of Area	1320 9.5	1426 9.5	66	627	4.0 100	0.010	<0.010	
19816 0927 68	OA TB3-H	2nd Floor - Room 218 - Center of Area	1350 9.5	1456 9.5	66	627	2.5 100	0.010	<0.010	

AM - AMBIENT AIR SAMPLE OA - OUTSIDE WORK AREA HP - EXHAUST OF HEPA NEGATIVE PRESSURE UNIT PS - PERSONAL AIR SAMPLE
 BS - BACKGROUND AIR SAMPLE FC - FINAL CLEARANCE WA - INSIDE WORK AREA EX - 30 MINUTE BREATHING ZONE DURING PEAK REMOVAL

ADVANCED AIR ANALYSIS, INC.

ASBESTOS AIR SAMPLING FORM

PROJECT NAME: Hilton ES

DATE: 9/27/2019

JOB # 19816

IH NAME: Timothy Brice / Michael Kagan SIGNATURE _____

OF SAMPLES: 73

PAGE # 4 OF 9

SAMPLE NUMBER	SAMPLE TYPE / PUMP ID	SAMPLE LOCATION	START TIME / FLOW	STOP TIME / FLOW	TOTAL TIME (MIN)	VOLUME (LITERS)	FIBERS/FIELDS	FIBERS/DET. LIMIT	F/CC	COMMENTS
19816 0927 08	FC TB5-H	1st Floor - Room 200 - Inside WA - Center of Area	0731 9.5	0837 9.5	66	627	5.0 100	0.010	<0.010	
19816 0927 09	FC TB6-H	1st Floor - Room 200 - Inside WA - Center of Area	0732 9.5	0838 9.5	66	627	3.0 100	0.010	<0.010	
19816 0927 10	FC TB7-H	1st Floor - Room 200 - Inside WA - Center of Area	0733 9.5	0839 9.5	66	627	2.5 100	0.010	<0.010	
19816 0927 11	FC TB8-H	1st Floor - Room 200 - Inside WA - Center of Area	0734 9.5	0840 9.5	66	627	4.0 100	0.010	<0.010	
19816 0927 12	FC TB9-H	1st Floor - Room 200 - Inside WA - Center of Area	0735 9.5	0841 9.5	66	627	3.0 100	0.010	<0.010	
19816 0927 15	FC TB10-H	1st Floor - Room 110 - Inside WA - Center of Area	0815 9.5	0921 9.5	66	627	2.5 100	0.010	<0.010	
19816 0927 16	FC TB11-H	1st Floor - Room 110 - Inside WA - Center of Area	0816 9.5	0922 9.5	66	627	4.5 100	0.010	<0.010	
19816 0927 17	FC TB12-H	2nd Floor - Room 209 - Inside WA - Center of Area	0817 9.5	0923 9.5	66	627	3.0 100	0.010	<0.010	
19816 0927 18	FC TB13-H	2nd Floor - Room 209 - Inside WA - Center of Area	0818 9.5	0924 9.5	66	627	2.0 100	0.010	<0.010	

AM - AMBIENT AIR SAMPLE OA - OUTSIDE WORK AREA HP - EXHAUST OF HEPA NEGATIVE PRESSURE UNIT PS - PERSONAL AIR SAMPLE
 BS - BACKGROUND AIR SAMPLE FC - FINAL CLEARANCE WA - INSIDE WORK AREA EX - 30 MINUTE BREATHING ZONE DURING PEAK REMOVAL

ADVANCED AIR ANALYSIS, INC.

ASBESTOS AIR SAMPLING FORM

PROJECT NAME: Hilton ES
 IH NAME: Timothy Brice / Michael Kagan SIGNATURE

DATE: 9/27/2019 JOB # 19816
 # OF SAMPLES: 73 PAGE # 5 OF 9

SAMPLE NUMBER	SAMPLE TYPE / PUMP ID	SAMPLE LOCATION	START TIME / FLOW	STOP TIME / FLOW	TOTAL TIME (MIN)	VOLUME (LITERS)	FIBERS / FIELDS	DET. LIMIT	F/CC	COMMENTS
19816 0927 19	FC TB14-H	2nd Floor - Room 209 - Inside WA - Center of Area	0819 9.5	0925 9.5	66	627	3.0 100	0.010	<0.010	
19816 0927 22	FC TB15-H	1st Floor - Room 111 - Inside - Center of Area	0911 9.5	1017 9.5	66	627	3.0 100	0.010	<0.010	
19816 0927 23	FC TB16-H	1st Floor - Room 111 - Inside - Center of Area	0912 9.5	1018 9.5	66	627	5.0 100	0.010	<0.010	
19816 0927 24	FC MK1-H	2nd Floor - Room 210 - Inside WA - Center of Area	0913 9.5	1019 9.5	66	627	2.5 100	0.010	<0.010	
19816 0927 25	FC MK2-H	2nd Floor - Room 210 - Inside WA - Center of Area	0914 9.5	1019 9.5	66	627	5.0 100	0.010	<0.010	
19816 0927 26	FC MK3-H	2nd Floor - Room 210 - Inside WA - Center of Area	0915 9.5	1020 9.5	66	627	2.5 100	0.010	<0.010	
19816 0927 29	FC TB5-H	1st Floor - Room 112 - Inside - Center of Area	1001 9.5	1107 9.5	66	627	3.5 100	0.010	<0.010	
19816 0927 30	FC TB6-H	1st Floor - Room 112 - Inside - Center of Area	1002 9.5	1108 9.5	66	627	3.0 100	0.010	<0.010	
19816 0927 31	FC MK4-H	1st Floor - Room 211 - Inside WA - Center of Area	1003 9.5	1109 9.5	66	627	4.5 100	0.010	<0.010	

AM - AMBIENT AIR SAMPLE OA - OUTSIDE WORK AREA HP - EXHAUST OF HEPA NEGATIVE PRESSURE UNIT PS - PERSONAL AIR SAMPLE
 BS - BACKGROUND AIR SAMPLE FC - FINAL CLEARANCE WA - INSIDE WORK AREA EX - 30 MINUTE BREATHING ZONE DURING PEAK REMOVAL

ADVANCED AIR ANALYSIS, INC.

ASBESTOS AIR SAMPLING FORM

PROJECT NAME: Hilton ES

DATE: 9/27/2019

JOB # 19816

IH NAME: Timothy Brice / Michael Kagan SIGNATURE

OF SAMPLES: 73

PAGE # 6 OF 9

SAMPLE NUMBER	SAMPLE TYPE / PUMP ID	SAMPLE LOCATION	START TIME / FLOW	STOP TIME / FLOW	TOTAL TIME (MIN)	VOLUME (LITERS)	FIBERS/FIELDS	DET. LIMIT	F/CC	COMMENTS
19816 0927 32	FC MK5-H	1st Floor - Room 211 - Inside WA - Center of Area	1004 9.5	1110 9.5	66	627	5.5 100	0.010	<0.010	
19816 0927 33	FC MK6-H	1st Floor - Room 211 - Inside WA - Center of Area	1005 9.5	1111 9.5	66	627	2.0 100	0.010	<0.010	
19816 0927 36	FC TB7-H	1st Floor - Room 113 - Inside WA - Center of Area	1056 9.5	1102 9.5	66	627	3.0 100	0.010	<0.010	
19816 0927 37	FC TB8-H	1st Floor - Room 113 - Inside WA - Center of Area	1057 9.5	1103 9.5	66	627	4.0 100	0.010	<0.010	
19816 0927 38	FC TB9-H	1st Floor - Room 212 - Inside WA - Center of Area	1058 9.5	1104 9.5	66	627	2.5 100	0.010	<0.010	
19816 0927 39	FC TB10-H	1st Floor - Room 212 - Inside WA - Center of Area	1059 9.5	1105 9.5	66	627	4.5 100	0.010	<0.010	
19816 0927 40	FC TB11-H	1st Floor - Room 212 - Inside WA - Center of Area	1100 9.5	1106 9.5	66	627	3.0 100	0.010	<0.010	
19816 0927 43	FC TB12-H	1st Floor - Room 114 - Inside WA - Center of Area	1131 9.5	1237 9.5	66	627	5.0 100	0.010	<0.010	
19816 0927 44	FC TB13-H	1st Floor - Room 114 - Inside WA - Center of Area	1132 9.5	1238 9.5	66	627	2.5 100	0.010	<0.010	

AM - AMBIENT AIR SAMPLE OA - OUTSIDE WORK AREA HP - EXHAUST OF HEPA NEGATIVE PRESSURE UNIT PS - PERSONAL AIR SAMPLE
 BS - BACKGROUND AIR SAMPLE FC - FINAL CLEARANCE WA - INSIDE WORK AREA EX - 30 MINUTE BREATHING ZONE DURING PEAK REMOVAL

ADVANCED AIR ANALYSIS, INC.

ASBESTOS AIR SAMPLING FORM

PROJECT NAME: Hilton ES

IH NAME: Timothy Brice / Michael Kagan SIGNATURE

DATE: 9/27/2019

JOB # 19816

OF SAMPLES: 73

PAGE # 7 OF 9

SAMPLE NUMBER	SAMPLE TYPE / PUMP ID	SAMPLE LOCATION	START TIME / FLOW	STOP TIME / FLOW	TOTAL TIME (MIN)	VOLUME (LITERS)	FIBERS / FIELDS	DET. LIMIT	F/CC	COMMENTS
19816 0927 45	FC TB14-H	1st Floor - Room 213 - Inside WA - Center of Area	1133 9.5	1239 9.5	66	627	4.0 100	0.010	<0.010	
19816 0927 46	FC TB15-H	1st Floor - Room 213 - Inside WA - Center of Area	1134 9.5	1240 9.5	66	627	3.5 100	0.010	<0.010	
19816 0927 47	FC TB16-H	1st Floor - Room 213 - Inside WA - Center of Area	1135 9.5	1241 9.5	66	627	3.5 100	0.010	<0.010	
19816 0927 50	FC TB5-H	1st Floor - Room 115 - Inside WA - Center of Area	1206 9.5	1312 9.5	66	627	2.0 100	0.010	<0.010	
19816 0927 51	FC TB6-H	1st Floor - Room 115 - Inside WA - Center of Area	1207 9.5	1313 9.5	66	627	4.5 100	0.010	<0.010	
19816 0927 52	FC MK1-H	1st Floor - Room 214 - Inside WA - Center of Area	1208 9.5	1314 9.5	66	627	3.0 100	0.010	<0.010	
19816 0927 53	FC MK2-H	1st Floor - Room 214 - Inside WA - Center of Area	1209 9.5	1315 9.5	66	627	4.0 100	0.010	<0.010	
19816 0927 54	FC MK3-H	1st Floor - Room 214 - Inside WA - Center of Area	1210 9.5	1316 9.5	66	627	3.5 100	0.010	<0.010	
19816 0927 57	FC TB7-H	1st Floor - Room 116 - Inside WA - Center of Area	1241 9.5	1347 9.5	66	627	5.5 100	0.010	<0.010	

AM - AMBIENT AIR SAMPLE BS - BACKGROUND AIR SAMPLE OA - OUTSIDE WORK AREA FC - FINAL CLEARANCE HP - EXHAUST OF HEPA NEGATIVE PRESSURE UNIT WA - INSIDE WORK AREA PS - PERSONAL AIR SAMPLE EX - 30 MINUTE BREATHING ZONE DURING PEAK REMOVAL

ADVANCED AIR ANALYSIS, INC.

ASBESTOS AIR SAMPLING FORM

PROJECT NAME: Hilton ES

DATE: 9/27/2019

JOB # 19816

IH NAME: Timothy Brice / Michael Kagan SIGNATURE _____

OF SAMPLES: 73

PAGE # 8 OF 9

SAMPLE NUMBER	SAMPLE TYPE / PUMP ID	SAMPLE LOCATION	START TIME / FLOW	STOP TIME / FLOW	TOTAL TIME (MIN)	VOLUME (LITERS)	FIBERS / FIELDS	DET. LIMIT	F/CC	COMMENTS
19816 0927 58	FC TB8-H	1st Floor - Room 116 - Inside WA - Center of Area	1242 9.5	1348 9.5	66	627	4.5 100	0.010	<0.010	
19816 0927 59	FC MK4-H	1st Floor - Room 216 - Inside WA - Center of Area	1243 9.5	1349 9.5	66	627	3.0 100	0.010	<0.010	
19816 0927 60	FC MK5-H	1st Floor - Room 216 - Inside WA - Center of Area	1244 9.5	1350 9.5	66	627	2.5 100	0.010	<0.010	
19816 0927 61	FC MK6-H	1st Floor - Room 216 - Inside WA - Center of Area	1245 9.5	1351 9.5	66	627	4.0 100	0.010	<0.010	
19816 0927 63	FC TB9-H	1st Floor - Room 117 - Inside WA - Center of Area	1321 9.5	1427 9.5	66	627	5.5 100	0.010	<0.010	
19816 0927 64	FC TB10-H	1st Floor - Room 117 - Inside WA - Center of Area	1322 9.5	1428 9.5	66	627	3.0 100	0.010	<0.010	
19816 0927 65	FC TB11-H	1st Floor - Room 217 - Inside WA - Center of Area	1323 9.5	1429 9.5	66	627	6.0 100	0.010	<0.010	
19816 0927 66	FC TB12-H	1st Floor - Room 217 - Inside WA - Center of Area	1324 9.5	1430 9.5	66	627	100	0.010	<0.010	
19816 0927 67	FC TB13-H	1st Floor - Room 217 - Inside WA - Center of Area	1325 9.5	1431 9.5	66	627	100	0.010	<0.010	

AM - AMBIENT AIR SAMPLE BS - BACKGROUND AIR SAMPLE FC - FINAL CLEARANCE OA - OUTSIDE WORK AREA HP - EXHAUST OF HEPA NEGATIVE PRESSURE UNIT PS - PERSONAL AIR SAMPLE WA - INSIDE WORK AREA EX - 30 MINUTE BREATHING ZONE DURING PEAK REMOVAL

ADVANCED AIR ANALYSIS, INC.

ASBESTOS AIR SAMPLING FORM

PROJECT NAME: Hilton ES

DATE: 9/27/2019

JOB # 19816

IH NAME: Timothy Brice / Michael Kagan SIGNATURE _____

OF SAMPLES: 73

PAGE # 9 OF 9

SAMPLE NUMBER	SAMPLE TYPE / PUMP ID	SAMPLE LOCATION	START TIME / FLOW	STOP TIME / FLOW	TOTAL TIME (MIN)	VOLUME (LITERS)	FIBERS/ FIELDS	DET. LIMIT	F/CC	COMMENTS
19816 0927 69	FC TB5-H	1st Floor - Room 218 - Inside WA - Center of Area	1351 9.5	1457 9.5	66	627	3.0 100	0.010	<0.010	
19816 0927 70	FC TB6-H	1st Floor - Room 218 - Inside WA - Center of Area	1352 9.5	1458 9.5	66	627	4.5 100	0.010	<0.010	
19816 0927 71	FC TB7-H	1st Floor - Room 218 - Inside WA - Center of Area	1353 9.5	1459 9.5	66	627	4.0 100	0.010	<0.010	
19816 0927 72	FC TB8-H	1st Floor - Room 218 - Inside WA - Center of Area	1354 9.5	1500 9.5	66	627	5.0 100	0.010	<0.010	
19816 0927 73	FC TB9-H	1st Floor - Room 218 - Inside WA - Center of Area	1355 9.5	1501 9.5	66	627	3.0 100	0.010	<0.010	

AM - AMBIENT AIR SAMPLE BS - BACKGROUND AIR SAMPLE OA - OUTSIDE WORK AREA FC - FINAL CLEARANCE HP - EXHAUST OF HEPA NEGATIVE PRESSURE UNIT WA - INSIDE WORK AREA PS - PERSONAL AIR SAMPLE EX - 30 MINUTE BREATHING ZONE DURING PEAK REMOVAL